

Security-Constrained Unit Commitment for Electricity Market: Modeling, Solution Methods, and Future Challenges

IEEE Task Force on Solving Large Scale Optimization Problems in Electricity Market and Power System Applications

Yonghong Chen¹, Senior Member, IEEE, Feng Pan, Feng Qiu², Alinson S Xavier³, Member, IEEE, Tongxin Zheng⁴, Senior Member, IEEE, Muhammad Marwali, Bernard Knueven, Yongpei Guan⁵, Fellow, IEEE, Peter B. Luh⁶, Life Fellow, IEEE, Lei Wu⁷, Fellow, IEEE, Bing Yan⁸, Member, IEEE, Mikhail A. Bragin⁹, Senior Member, IEEE, Haiwang Zhong¹⁰, Senior Member, IEEE, Anthony Giacomoni¹¹, Ross Baldick¹², Fellow, IEEE, Boris Gisin, Member, IEEE, Qun Gu, Russ Philbrick, and Fangxing Li¹³, Fellow, IEEE

Abstract—This paper summarizes the technical activities of the IEEE Task Force on Solving Large Scale Optimization Problems in Electricity Market and Power System Applications. This Task Force was established by the IEEE Technology and Innovation

Subcommittee to first review the state-of-the-art of the security-constrained unit commitment (SCUC) business model, its mathematical formulation, and solution techniques in solving electricity market clearing problems. The Task Force then investigated the emerging challenges of future market clearing problems and presented efforts in building benchmark mathematical and business models.

Index Terms—Combined cycle, decomposition, distributed energy resource, electricity market, mixed-integer programming, network security analysis, relaxation, security-constrained unit commitment, storage, virtual transaction.

Manuscript received 2 April 2022; revised 14 August 2022; accepted 3 October 2022. Date of publication 10 October 2022; date of current version 21 August 2023. Paper no. TPWRS-00471-2022. (Corresponding author: Yonghong Chen.)

Yonghong Chen is with the Midcontinent Independent System Operator Inc, Carmel, IN 46032-3826 USA (e-mail: chen_yh01@hotmail.com).

Feng Pan is with the Electricity Infrastructure, Pacific Northwest National Laboratory, Richland, WA 99532 USA (e-mail: feng.pan@pnl.gov).

Feng Qiu is with the Argonne National Laboratory, Lemont 60439 USA (e-mail: fqiu@anl.gov).

Alinson S Xavier is with the Argonne National Laboratory, Argonne, IL 60439 USA (e-mail: axavier@anl.gov).

Tongxin Zheng is with the ISO New England, Holyoke, MA 01040 USA (e-mail: tzheng@iso-ne.com).

Muhammad Marwali is with the NYISO, Rensselaer, NY 12144 USA (e-mail: mmarwali@nyiso.com).

Bernard Knueven is with the Computational Science Center, National Renewable Energy Laboratory, Golden, CO 80401 USA (e-mail: bernard.knueven@nrel.gov).

Yongpei Guan is with the Industrial and Systems Engineering, University of Florida, Gainesville, FL 32611 USA (e-mail: guan@ise.ufl.edu).

Peter B. Luh is with the Computer Engineering, University of Connecticut, Storrs, CT 06269-2157 USA (e-mail: peter.luh@uconn.edu).

Lei Wu is with the Stevens Institute of Technology, Hoboken, NJ 07030 USA (e-mail: lwu11@stevens.edu).

Bing Yan is with the Electrical and Microelectronic Engineering, Rochester Institute of Technology, Rochester, NY 14623-5603 USA (e-mail: bxeyee@rit.edu).

Mikhail A. Bragin is with the Electrical and Computer Engineering, University of Connecticut, Storrs, CT 06269 USA (e-mail: mbragin@engr.uconn.edu).

Haiwang Zhong is with the Electrical Engineering, Tsinghua University, Beijing 100084, China (e-mail: zhonghw@mail.tsinghua.edu.cn).

Anthony Giacomoni is with the PJM, Audubon, PA 19403 USA (e-mail: anthony.giacomoni@pjm.com).

Ross Baldick is with the Electrical and Computer Engineering, University of Texas, Austin, TX 78712 USA (e-mail: baldick@ece.utexas.edu).

Boris Gisin and Qun Gu are with the PowerGEM Limited Liability Company, Clifton Park, NY 12065 USA (e-mail: bgisin@power-gem.com; qgu@power-gem.com).

Russ Philbrick is with the Polaris Systems Optimization, Shoreline, WA 98177-2468 USA (e-mail: russ.philbrick@psopt.com).

Fangxing Li is with the EECS, University of Tennessee, Knoxville, TN 37996 USA (e-mail: fli6@utk.edu).

Color versions of one or more figures in this article are available at <https://doi.org/10.1109/TPWRS.2022.3213001>.

Digital Object Identifier 10.1109/TPWRS.2022.3213001

I. INTRODUCTION

FERC landmark Orders 888 and 889 gave rise to the formation of independent system operators (ISOs) in the late 1990s. The ISOs formed wholesale electricity markets to foster competition among generating resources through hourly and sub-hourly prices. Grid operators must balance the instantaneous generation and consumption of electricity over various time-frames through control, dispatch, commitment, and procurement of energy and ancillary service products.

Maintaining grid security and reliability is a critical component of all electricity markets. In addition to balancing supply and demand under various system conditions, ISOs need to maximize the efficient use of the region's resources and transmission network through day-ahead and real-time markets and additional reliability commitment processes. The core of the market clearing and reliability commitment processes is the security constrained unit commitment (SCUC) and security-constrained economic dispatch (SCED) software. The market clearing optimization software enables ISOs to unlock billions of dollars of benefits to society [1].

The SCUC problem has been studied extensively in the literature. Mathematically, the SCUC problem is a nonconvex, large-scale, mixed-integer optimization problem with a large number of binary and continuous variables as well as a series

of prevalent equality and inequality constraints. The objective is the maximization of social welfare. However, traditionally the demand side is mostly inelastic and the objective is usually formulated as minimizing production cost plus the constraint violation penalties. The production cost usually includes startup, no-load, and incremental energy costs represented by piecewise linear functions. The SCUC model of a large-scale ISO such as MISO and PJM may have 36 time intervals with over 1000 generators and 10000 monitored transmission elements. In addition, enforcing the N-1 security standard in market clearing makes the SCUC problem almost impossible to solve directly, often requiring a decomposition scheme or iterations between optimization solver and network security analysis software.

SCUC constraints include resource-level constraints and system-wide constraints. Resource-level constraints are used to represent the physical operating characteristics of generators and other resources. They include capacity limits, ramp rate limits, minimum run times, minimum down times, etc. These constraints may link binary and continuous variables across multiple time intervals. System-wide constraints mainly include power balance constraints, reserve requirement constraints, and transmission constraints. Transmission constraints are enforced to meet North American Electric Reliability Corporation (NERC) N-1 and other reliability standards. They are usually associated with continuous variables and are often decoupled by time intervals.

In the early years of the electricity markets, SCUC used in the market clearing process was mostly solved by the Lagrangian Relaxation (LR) method. With the development of more advanced commercial mixed-integer linear programming (MILP) solvers, it became practical to replace LR with MILP with the first deployment by PJM in 2004 [150]. Since then, most ISOs have switched to using MILP solvers to solve SCUC problems. Nevertheless, in view of the increased complexity in the presence of intermittent renewables, distributed energy resources (DERs), and sub-hourly commitment, there is a renewed interest in the study of LR-based decomposition and coordination approaches.

Traditionally, SCUC solution efficiency is usually driven by the number of binary variables, the number of security constraints, and the presence of loosely coupled decision variables such as those for storage state-of-charge management and combined-cycle generation, etc. With rapidly evolving power-grid operations, the drastically increasing complexity of market clearing models requires a continuing focus on improving the performance of SCUC optimization models and methods.

This paper focuses on the deterministic SCUC problem that is currently used in the electricity market clearing. Sections II and III review the state-of-the-art of the SCUC business model, its mathematical formulation, and solution techniques. Sections IV and V focus on the emerging challenges and efforts in building benchmark mathematical and business models. Section VI is the conclusion.

II. SCUC MODELING

A. Business Model

The electricity market provides a mechanism for market participants to buy and sell electrical energy at prices




Fig. 1. SCUC and SFT iteration for market clearing.

established through a competitive auction process designed to meet energy demands (i.e., loads) and system reliability requirements with the least-cost resources available, or through contractual bilateral transactions. The ISO administers day-ahead and real-time markets, resulting in a two-settlement process. Due to the greater number of hours that must be considered when solving day-ahead SCUC, this usually presents the most computational challenges.

- In practice, the SCUC problem includes two components: a MILP optimization problem and a security analysis problem [2]. Theoretically, the two components can be combined into one multi-interval Alternating Current Optimal Power Flow (AC-OPF) problem. In practice, the industry has taken advantage of the advanced technologies for solving Direct Current Optimal Power Flow (DC-OPF) and MILP, arriving at the current structure as follows:
- ISOs clear the market to optimize multi-interval active power schedules. Reactive power scheduling and voltage controls are mainly managed in a separate process outside of the market and applied as linear constraints on active power [3]. Losses are included in the load forecast. The impact of losses on efficient dispatch is represented by “penalty factors”, as a linear marginal loss function [4], [182].
- SCUC optimization and network analysis are solved iteratively. The network analysis part is sometimes referred to as the simultaneous feasibility test (SFT).
- SFT identifies violated base case and contingency constraints using power flow and contingency analysis. New constraints from SFT are linearized and reported using generation shift factors (GSFs).
- The new constraints are added to solve the next iteration of the SCUC optimization problem. Some applications may also update marginal loss factors using updated power-flow results [7].

In addition, PJM and MISO also use SCUC for after-the-fact performance analysis, where full-day sub-hourly SCUC is solved using actual data to benchmark production performance and provide guidance to operational practice under uncertainty. PJM has reported significant savings [18].

As the mix of resources has evolved in recent years, the traditional SCUC model has started to show limitations in representing emerging resources [8], [9], [10]. Consequently, there is a tradeoff between the need for accurate resource modeling

and the need for reducing computational burdens. Section IV discusses emerging challenges with the current MILP solver.

B. Basic Mathematic Formulation

At a high level, SCUC can be seen as minimizing the operating cost of the given set of resources, subject to the physical constraints of both the system as a whole and individual resources, as follows:

$$\begin{aligned} \text{Minimize :} \\ f = \sum_{g \in G} c_g \end{aligned} \quad (\text{SCUC.1})$$

$$\begin{aligned} \text{Subject To :} \\ \sum_{g \in G} (A_g p_g + B_g u_g) = D \end{aligned} \quad (\text{SCUC.2})$$

$$(p_g, u_g, c_g) \in \Pi_g \quad \forall g \in G \quad (\text{SCUC.3})$$

Here the set of equations (SCUC.3) abstractly represents the physical constraints of individual resources g , with continuous production variables p_g , binary status variables u_g , and associated cost c_g . The equations (SCUC.2) abstractly represent the physical and/or operational constraints on the transmission system, e.g., those that the ISO determines. These include energy balance, reserve requirements, and transmission limits. (SCUC.1) minimizes the total cost to operate the system.

A 3-binary SCUC formulation is presented in the Appendix.

C. Modeling of Security Constraints

The security constraints in the context of SCUC refer to transmission limit constraints under both normal operating conditions and contingency conditions. There are primarily two formulations used in academic study and industry to formulate power flows and model transmission constraints. The first one, traditionally referred to as the ‘‘B-theta’’ formulation, directly models voltage phase angles and power flows. The second way to model transmission constraints is to use the power transfer distribution factor (PTDF) or GSF matrix. It is nearly impossible to model N-1 constraints in the phase-angle formulation. As algorithms (e.g., [19]) have been developed to effectively filter unnecessary security constraints and new PTDF-based formulations (e.g., [20], [172], [173]) are developed for modeling flexibility, there is little benefit to use phase-angle formulations anymore. Practical ISO applications mainly use the PTDF-based approaches.

III. STATE OF THE ART SOLUTION METHOD

A. Strengthening MILP Formulation for Performance Improvement

Most researchers formulate SCUC as a MILP model. Researchers have attempted to strengthen the MILP formulation of SCUC from the perspective of two metrics: compactness and tightness [22].

An important method for improving compactness is to remove redundant constraints and non-binding constraints [34], [35], [36], [37], [131]. Another way to improve the compactness is to reduce the number of binary variables. Similar plants are

grouped into clusters to reduce binary variables in [38]. The work [39] further reveals the errors in clustering and provides near-optimal schedules on a plant level.

An ideally tight MILP formulation yields a linear programming (LP) relaxed feasible region that is identical to the convex hull of the feasible integer points. In this case, the optimal solution of MILP can be obtained simply via solving LP relaxation [21]. The tightness is usually measured with the ‘‘integrality gap’’ (IntGap) [22], [23], [24]. Another measurement is the integrality gap in the root node (RootIGap) [25].

The unit commitment polytope has been studied extensively and there are different formulation approaches for individual generators. The formulations are different depending on distinct modeling approaches for the binary logic restrictions, minimum up/down time formulation, ramping up/down constraints, startup costs, and piecewise linear production costs.

For instance, there are different ways to choose binary variables. A compact formulation using one binary variable (1-bin: on/off) is presented in [28]. Based on these single binary decision variables, alternating up/down inequalities are presented in [31] to strengthen the minimum-up/down polytope by providing its convex hull description. In other papers (e.g., [22], [23], [30]), three or two binary decision variables for each generator are utilized. For the three-binary decision variable approaches, the convex hull of the minimum-up/-down time polytope is introduced in [40]. When the studies are extended to provide strong formulations including ramping constraints, new families of inequalities are presented in [23], [41], and [42] to tighten the ramping polytope. Reference [29] replaces the on/off variable in 3-bin with one binary variable depicting the state transition. In [41], the convex hull descriptions for the two-period and three-period cases have been provided. When all constraints are considered, there are no convex hull descriptions for the general case setting by using the one-binary, two-binary, or three-binary decision variables. Probably the best current integral UC formulation for individual generators considering all the constraints plus piecewise linear objective function is provided in a higher-dimensional space shown in [43], which is formulated by introducing binary decision variables to represent the ‘‘on’’ and ‘‘off’’ intervals (instead of individual time periods), requiring $O(T^2)$ binary decision variables and $O(T^3)$ continuous decision variables. A few additional recent papers have analyzed the polyhedral aspects of the interaction of the system constraints with the generator’s technical constraints [33], [44], [45]. Finally, two recent papers attempt to assess the current state-of-the-art in unit commitment formulations [21], [46].

Besides the constraints, [45] and [47] report tightening the piece-wise linear formulations for the incremental energy cost function in the objective to achieve the convex envelope of the objective function. This is further incorporated in [43] in a higher-dimensional space. A tighter linear approximation of the nonlinear objective function of units is presented in [32]. Most of the above works present tightened formulations, possibly with proofs. In [33], a systematic approach is developed to tighten formulations.

In practice, industrial-scale UC problems are today solved by utilizing off-the-shelf commercial MILP solvers such as

CPLEX, GUROBI, or XPRESS. Such solvers employ a heavily embellished version of the LP-based branch-and-cut (B&C) algorithm. The compact formulations and cutting planes can be embedded in the B&C framework to speed up the algorithm for solving the problem. Hence, benchmarking on realistic and diverse test cases is essential to quantify the performance of a SCUC formulation with a given solver. For a comprehensive overview of modern B&C methods, see [159].

B. Decomposition and Coordination Methods

LR was traditionally used to solve UC problems by exploiting separability, with subgradient methods to update multipliers [48]. Standard LR, however, suffers from difficulties such as significant computational requirements to obtain subgradients and zigzagging of multipliers. Major difficulties of LR have been overcome by the recently developed surrogate LR (SLR) [49], in which surrogate subgradient directions are obtained after solving one or a few subproblems subject to the simple “surrogate optimality condition” to ensure that the relaxed problem is sufficiently optimized. Computational effort and multiplier zigzagging are much reduced since only one or a few subproblems are solved at a time. SLR has been further improved by adding absolute value penalties (which can be exactly linearized) on constraint violations to accelerate convergence [50].

C. Other Decomposition Methods

The ways to decompose a UC problem mostly fall into two categories: temporal decomposition [51], [52] and geographic decomposition [53]. As the modern MILP solvers have become very efficient in solving SCUC, especially with the help of well-designed algorithms, e.g., machine learning enhanced optimization [54], decomposition does not give much benefit to solving SCUC in terms of solution time. However, a decomposable SCUC is useful for decentralized resource scheduling, such as inter-market energy exchange and loop flow mitigation [56], [57].

D. Primal Heuristics

Primal heuristics are usually used to provide high-quality feasible solutions for MILPs at a relatively low computational expense [58], [59], [60]. Most primal heuristics can be divided into two folds of LP-based heuristics [60], [62], [63] and MILP-based heuristics [61], [64], [65], [66], [67]. Metaheuristic methods perform well in finding high-quality solutions for warm starts with primal heuristics [68], [69], [70], [71], [72], [73], [74]. Recently, the application of machine learning in the solution of UC has been attracting many research interests. Several machine learning methods are presented in [54].

For large-scale day-ahead market clearing problems, in addition to binary variables associated with resource commitments, large numbers of transmission constraints coupled with a large number of continuous variables (usually from virtual transactions) can also drive computational challenges. In [75], the heuristic binary reduction and transmission constraint decomposition methods are developed and implemented at MISO as a heuristic “backup” method for the rare instance that the

MILP solver faces difficulty reaching its tolerance. In [76], this “polishing” heuristic method is further integrated with the optimization solvers as a warm start technique through “MIP start” and lazy constraint settings.

Several effective primal heuristic methods including the enhanced polishing method, variable fixing, and enhanced RINS (RINS-E) are developed under the High-Performance Power Grid Optimization (HIPPO) project funded by the Department of Energy’s ARPA-E program [77], [78]. The concurrent SCUC architecture built under HIPPO allows these approaches to be implemented concurrently with significant performance improvement.

IV. EMERGING CHALLENGES

The SCUC model mainly consists of resource and transmission constraints. With the evolution of portfolio, traditional generators are augmented by emerging resources. Each new resource type introduces certain unique challenges. This section discusses emerging challenges driven by future resource and grid changes such as demand response and massive DERs [11], short-time-interval scheduling [12], increasing binding transmission due to insufficient security margins [13], and diverse operational characteristics [16]. The interdependency with the natural gas network and the market clearing price mechanism are also discussed.

A. Combined Cycle

Configuration-based combined-cycle gas turbines (CCGTs) make up the majority of all new generation capacity created over the last decade. The fast response time and operational flexibility of CCGTs make them valuable resources for mitigating the variability and uncertainty of intermittent renewable energy. Six CCGT models currently exist in academic research and industry practice: Aggregate Model [79], [80], Pseudo Unit Model [79], Component-Based Model [80], [81], Configuration-Based Model [47], [80], [82], [83], [84], [85], Edge-Based Model [86], [87], and Configuration-Component Based Hybrid Model [88]. The configuration-component based hybrid model maps the relationship between the configuration-based model and component-based model without introducing additional binary variables, allowing more accurate constraint formulations on the configuration or component level.

In [89], a transition curve model is presented to reflect the transition process. The column aggregation methods in [47] and warm start methods in [76] are useful for SCUC problems in general, and particularly helpful for the configuration-based CCGT model.

In [91], the Surrogate Augmented LR (SALR), an earlier version of the Surrogate Absolute Value LR (SAVLR) [50], is developed for effective coordination and accelerated convergence. The method may outperform MIP solvers in finding optimal solutions within tolerance for stressed MISO cases.

B. Electric Energy Storage

FERC Order 841 [92] requires each ISO to establish a wholesale market participation model for electric storage resources.

The Order does not specifically require ISOs to optimize the state of the charge (SOC). Recently, storage-plus-generation co-located hybrid resources have been increasing as a share of newly proposed projects and participants are seeking self-optimizing opportunities [93].

Some ISOs (e.g., PJM) optimize pumped storage hydro in the day-ahead market [94]. Even though most ISOs do not currently optimize SOC for battery storage, the SOC is an essential aspect of the operating characteristics of storage. As discussed both theoretically and empirically in [95], the combination of mutually exclusive charging and discharging modes together with SOC limits and round-trip efficiency strictly less than one presents a computational challenge. This subsection focuses on the storage model in day-ahead SCUC. It requires a more sophisticated representation of the potential future value of stored energy that may be realized in the real-time market when the solution window is shorter than the storage duration.

1) *Pumped Storage Hydro (PSH)*: In some RTOs, the PSH may simply offer to generate power and bid to buy power for pumping, analogous to the participation of thermal generators, but typically with some additional features such as maximum daily energy for the generating mode to represent SOC limits. The maximum daily energy constraints are also used for other fuel-constrained resources [6]. Some other RTOs (e.g., PJM) have partially integrated the representation of PSH characteristics into their day-ahead unit commitment model [94]. PSH optimization in SCUC may introduce computational challenges.

PSH modeling has been studied in the literature [96], [97], [98], [99], [100], [101], [102], [103], [104]. Reference [105] introduces a configuration-based PSH model stemming from the configuration-based CCGT model presented in [47] and [80]. It is combined with the SOC constraints that have been widely used in the literature. Transitions between each pair of modes are modeled specifically. In [95], valid inequalities are derived for PSH with two binary variables to represent mutual exclusivity amongst three PSH configurations (i.e., pumping, generating, and off) and describe SOC.

Besides formulating and solving PSH directly with a MILP-based SCUC model, PJM optimizes PSH after the MILP-based day-ahead SCUC clearing engine using a customized non-MILP based software [7], [94].

2) *Battery Storage*: In general, even though battery storage can be smoothly dispatched across charging and discharging modes, battery storage formulations still require binary variables due to the mutual exclusiveness between charging and discharging modes. Formulations for battery storage are discussed in [106] and [107] with exact relaxation methods based on assumptions on the charging and discharging offers. The methods may not be general enough to cover all possible offers or when the SOC limits are binding. References [108] and [109] prove sufficient conditions under which the battery storage formulation can be relaxed to the convex form in the economic dispatch model. NYISO presented its modeling of storage in the dispatch-only model with binary variables introduced for battery storage [111].

Reference [110] investigates the impact of optimizing battery storage on computational performance and the potential

economic benefit, with a case study based on MISO day-ahead SCUC. It investigates the impact of battery storage binary variables, valid inequality constraints from [95], and explicit representation of battery SOC on the performance of day-ahead SCUC.

One of the most important components in the operational costs of battery energy storage systems is degradation. Various degradation models are presented in [151], [152], [153], [154], [155], [156], [157], [158]. For a more in-depth review, see [151]. In general, these models present challenges in balancing the formulation accuracy and the computation complexity.

C. Demand Side Participation and Distributed Energy Resource

Most ISOs allow demand side to participate in the energy and ancillary service markets. However, the participation has been relatively low. The policy discussions may be found in [191], [192]. Dispatchable demand may be incorporated into the market clearing process by changing the objective to maximizing social welfare, and adding variables and constraints associated with dispatchable demands [193], [112], [113].

The power industry has been exploring effective approaches to facilitating the participation of DERs in the ISO market, including the recent FERC Order 2222 [11]. However, under the current locational marginal price (LMP)-based electricity market practice, resources are usually only allowed to aggregate under a single elemental pricing node (Epnode) where LMP is calculated. DERs may be incorporated into SCUC formulation as aggregation of homogenous or heterogenous generation. This may introduce a large number of small resources with a large number of variables and increase computational complexity. Practical SCUC MILP solutions are usually solved with a tolerance of a non-zero MILP gap. MILP solvers may not solve the binary variables associated with a small resource to the optimal if the total cost of the resource is less than the MILP gap. MISO [75] has a “polishing” method to refine commitment variables for out-of-money units, and NYISO [6] has a method to fix commitment variables for large resources and solve the commitment of small resources to a smaller MILP gap. In addition, the work in [112] and [113] leads to the possibility to represent demand response (DR) assets or even DERs with convex polytope approximation, which can potentially address the small resource issue without considering transmission constraints. However, aggregating small-scale DERs across locations with different LMPs introduces conflicts with the fundamental principle of the nodal electricity market.

Currently, distribution factors [114] are used to describe the ratios of individual DERs to the total power of the aggregated commercial pricing node (Cpnode). The distribution factor-based approximation model for aggregated DERs may introduce inevitable errors to power flows of individual transmission lines, leading to market clearing solutions that are suboptimal or even infeasible to the actual physical system. Some suggest that state estimation results may be used to update distribution factors for the rolling real-time SCED (RT-SCED) calculations. However, this feedback strategy may induce oscillations of LMPs and

dispatches of generators and DERs as observed in recent studies [115], [116].

The distributed transmission system operator (TSO) and distribution system operator (DSO) coordination approaches have been studied in the literature [117], [118], [119], [120]. Alternatively, a feasible region projection-based approach is recently explored [121], [122] to study the integration of DER-penetrated distribution systems into ISO market operation.

D. Virtual Transactions

Virtual transactions are financial contracts awarded in the day-ahead market and settled at the differences between day-ahead and real-time prices. Most ISOs include virtual incremental offers (INCs) that are similar to generation offers and virtual decremental bids (DECs) that are similar to demand bids. Some ISOs also implemented up-to-congestion bids (UTCs) (see detail in [123]). The mathematical formulation of a virtual INC or DEC is relatively simple, only involving a continuous variable defined for a specific time interval at a pricing node with a dispatch range between 0 and the maximum offered MW. However, a large number of virtual transactions may increase the number of decision variables and the time for a MILP solver to solve each LP [75]. It has been shown in [47] that combining variables with the same coefficient in transmission security constraints (i.e., column aggregation) could improve computational performance.

ERCOT also allows the blocking of UTC bids that require binary variables [124]. Inherently UTCs are a very low-risk transaction as explained in [125]. The number of UTCs can be very large and may have a more significant impact on congestion than INC/DEC bids. They may cause slow convergence between SCUC and network security analysis SFT [124], [125]. It is also debatable whether virtual INC/DEC bids and UTCs can cause line loss. UTCs often cause significant marginal loss convergence difficulties.

In general, the model of INCs and DECs can be applied as the simplest DER model. The experience with virtuals may provide insights on future computational impact from DERs.

E. Sub-Hourly Unit Commitment

Day-ahead SCUC is traditionally formulated and solved with one hour as a time interval. Increasing dynamics on the grid prompted the industry to consider whether SCUC with sub-hourly intervals may improve system flexibility and reliability. However, it is much more complex than hourly UC because 1) the increased number of periods leads to larger problem sizes, and 2) the much-reduced unit ramping capabilities per period result in more complicated convex hulls. Existing ramp constraint formulations, using a 3-binary SCUC formulation, usually capture the convex hull for only 2 or 3 periods [41].

In [77], the approach of concurrently solving the hourly interval SCUC to warm start 15-min interval SCUC is developed in HIPPO. The greedy method with sequential neighborhood search can effectively find high-quality incumbent solutions.

The recently developed SAVLR method [50] overcomes the major difficulties of traditional LR and has accelerated convergence through absolute-value penalty terms on constraint violations. A novel approach is further developed in [127] to only relax system demand constraints and keep system reserve and transmission capacity constraints as “soft constraints” following the approach in [130]. Furthermore, the Ordinal Optimization (OO) concepts [128], [129] are applied to generate good-enough subproblem solutions quickly without calling B&C in most cases. The results demonstrate that SAVLR+OO+B&C obtains near-optimal solutions in a computationally efficient manner for multiple difficult sub-hourly UC cases, significantly outperforms B&C, and is robust.

F. Large Scale Transmission System

With the penetration of distributed resources and more binding transmission constraints, it is important to investigate better formulations for transmission constraints in SCUC modeling. The work in [14] presents a fast SCUC for large-scale power systems with heuristics. In [15], transmission-constrained UC is presented, which considers both electricity and district heating networks. However, it is still a difficult problem to formulate. DERs introduce new challenges to transmission and distribution coordination.

Existing research focuses on improving the transmission security constraint representation by identifying active constraints while excluding the redundant ones [131], [132]. It has been shown in [47] that column aggregation could improve computational performance. References [133] and [134] further explore column-based aggregations for complicated transmission security constraints.

In [116] and [135], the column-based aggregation approach is used to aggregate variables of pricing nodes with similar sensitivity factors based on a pre-defined threshold. It can reduce variables in transmission security constraints thresholds while ensuring feasibility to the original network security constraints.

In [75], it shows that usually only less than 20% of the pre-identified “watchlist” transmission constraints are binding in MISO day-ahead SCUC. The Gurobi solver provides three different settings on the “Lazy” constraint attributes [136]. Using the lazy constraint settings can reduce the computational burden while maintaining the original problem definition. In [76], a “warm start” method is developed to identify unlikely-to-bind transmission constraints and set them as “lazy”. In [90], the screening method is combined with lazy constraints to leverage mathematical modeling and historical data.

In practice, SCUC is solved interactively with the simultaneous feasibility test (SFT). In traditional approaches, partial refactorization algorithms are used [137]. The extremely fast PYSFT using Python open-source sparse matrix library implemented in HIPPO [78], [171] takes advantage of the fact that the base case and a contingency case only differ by a small number of elements. The Sherman-Morrison-Woodbury formulation [162] can be used to update the inverted low-rank contingency admittance matrices. Faster low-rank factorizations enable the SFT solver to be called in the process of solving

MILP through MILP solvers like GUROBI and CPLEX via their callback API. The combination of low-rank factorization and concurrent approach drastically reduced computation time in experimenting on large-scale SCUC cases [78].

G. MW Dependent Ramp Rate

Traditionally, a unit's ramp rate is modeled as a constant, which means it does not change with respect to the output level of a generator. Unfortunately, this can sometimes be far from reality. For instance, a CCGT can be represented by one pseudo generator with an operating range covering different configurations. When the generator is dispatched from one configuration to another, transition time is often required, indicating a very slow ramp rate. In addition, the ramp rates in different configurations are often different.

To improve the modeling accuracy, the MW-dependent ramp rate is introduced. In [138], the MW-dependent ramp rate curve is represented by a piecewise step function of the generation output level. A single-interval dispatch model based on special ordered set type 2 (SOS2) constraints is developed for the ISO-NE market. It can be expanded for the multi-interval SCUC problem with respect to both energy and reserve products. The formulation can be solved with the built-in SOS2 variables in a commercial MILP solver. However, the SCUC performance using the built-in SOS2 method can be degraded significantly as the number of ramp rate curves increases. An efficient formulation such as [139] and/or solution methods need to be further investigated.

NYISO models its MW-dependent ramp rate curve using binary variables to improve performance. A piecewise linear function can be easily modeled using binary variables [140]. NYISO experiences show that performance is significantly improved with the binary variables.

H. Gas Network

With the increasing interdependency between the power system and other infrastructures, electricity market clearing is also impacted by the physical restrictions and market operations of those infrastructures. One such example is the interdependency of the electricity grid and natural gas network, and the interdependency is intensified by the increasing numbers of gas-fired generating units and flexible multi-energy users that participate in both electricity and gas markets [174], [175], [176]. For instance, gas prices of the natural gas market influence prices of the electricity market through bidding strategies of natural gas units [177]. Gas availability, which depends on the gas network, may compromise the operational security of the electricity grid [178]. Also, interval optimization is employed in [179] to address uncertainty in the interdependent operation of both networks. Coordinating the two markets has thus attracted increasing attention in recent years and is believed to be able to derive more satisfactory solutions than optimized separately.

Various strategies have been discussed in the literature to coordinate the electricity grid and the natural gas system in terms of energy market design and pricing in addition to market scheduling [175], including: (i) incorporating natural gas

network constraints in electricity market clearing models; (ii) incorporating dynamic gas consumptions of the electric power system in natural gas market clearing models; (iii) sequentially optimizing the electricity grid and the natural gas network; (iv) co-optimizing the electricity grid and the natural gas network; and (v) time alignment of electricity and natural gas markets.

Nevertheless, the coordination and integration mechanisms of these two markets are still at a preliminary stage, because electricity and natural gas pricing are currently settled in two markets that are organized separately. Moreover, an energy company participating in both electricity and gas markets usually has independent decision-making processes with two distinct optimization models, although strategic behaviors of gas producers/consumers in the gas market may also influence electricity market operations. Advanced energy management strategies and market interactions involved in the two markets should be further investigated to capturing their distinct physical restrictions and market operations such as speed of energy flows, capability of large-scale energy storage, and flexibility in network operations.

I. Market Clearing Price

Locational marginal pricing (LMP) has become the dominant pricing scheme in all major US and some European electricity markets [4], [17], [180], [181], [182]. The concept is originally presented in [17], [180] to achieve optimal resource allocation, provide economic incentives and manage congestions. LMP is often derived from a convex security-constraint economic dispatch (SCED) problem, which takes the commitment solution from a SCUC problem. LMP provides supports for the SCED solution, but revenue from LMP may not cover the total cost including the commitment cost. It is shown in [183] that LMPs plus make-whole payments are equilibrium prices for generation resources.

Different pricing schemes for markets with non-convexities are presented. A comprehensive review is provided in [187]. Convex hull pricing (CHP) [184] is a pricing scheme that minimizes uplift payments over all possible uniform prices. Various methods are presented to solve CHP [185], [186], [187], [188]. Average incremental cost (AIC) pricing is presented to eliminate the make-whole payment [189], [190].

Renewable integration creates new challenges in the pricing of electricity due to low marginal costs of renewables. Improving price signal to manage increasing variability and uncertainty becomes an important research topic in recent years. This part will be covered in a future report.

V. BENCHMARK

A. Formulation

In its general form, SCUC is an NP-hard optimization problem [141]. Therefore, benchmarking against realistic test instances is important in any computational approach to SCUC. Because SCUC is typically solved with off-the-shelf MILP solvers, improvements to the base formulation (SCUC.1)-(SCUC.3) have been of special interest.

Many researchers attempt to scale up an instance of the SCUC problem by considering a basic set of generating units and replicating them several times [28], [23], [22], sometimes with an objective function perturbation [21]. Such approaches introduce artificial symmetry into the SCUC instance, making the corresponding MILP problems much more difficult for MILP solvers, even those with sophisticated symmetry detection techniques [142].

More recently, more realistic and diverse sets of publicly available generator data have been easier to come by. Perhaps the first instance of this is the test system provided by FERC [143]. The RTS-GMLC test system [144] includes transmission, reserve, load, and renewable generation for an entire synthetic year, however, it is small-scale, consisting of only 158 units and 73 buses. The Power Grib Lib – Unit Commitment [145] (pglib-uc) test library includes modified versions of both test systems, along with an additional test system based on publicly available data from California ISO, for a total of 56 cases. However, no transmission network data is included. Finally, the aforementioned test instances and additional cases with transmission network based on MATPOWER OPF instances are all available as part of the UnitCommitment.jl package [146].

Most papers consider a fixed set of formulations for SCUC. Perhaps the largest such set of formulations is compared in [46], which considers 12 base formulations against the 56 test cases from pglib-uc. Against its recommended formulation “Tight (T)”, [46] undertakes a comprehensive analysis, swapping a single component of the formulation at a time for a competitor. Additionally, [46] introduces the idea of exploring the *space of SCUC formulations*. The different formulations explored in [46] are available as Pyomo [147] models as part of the Egret software package [148] – enabling the exploration of over 100000 different SCUC formulations.

B. UnitCommitment.jl

The IEEE Task Force on Solving Large-Scale Optimization Problems in Electricity Markets has started the development of UnitCommitment.jl [146], [149], an extensible open-source Julia/JuMP optimization package for the problem. The package contains four main components.

First, the package includes an extensible and fully documented JSON-based data format to describe the most important aspects of the problem. It can also be easily extended with new sections and new data fields.

Second, the package includes two classes of diverse collections of large-scale benchmark instances. The first class is composed of instances previously presented in the literature. Included are both randomly generated instances used in previous studies [21], [163], [164], as well as instances based on more realistic systems [46], [143], [144]. The package also includes a second class of newly developed instances, originally based on realistic optimal power flow (OPF) test cases from MATPOWER and augmented through machine learning models trained on public real-world bid and offer data.

Third, UnitCommitment.jl provides a growing collection of Julia/JuMP implementations of SCUC formulations,

including ramping [22], [168], [169], [170] and piecewise-linear costs [26], [28], [55]. In addition to formulations, the package also includes implementations of contingency screening methods [19].

Fourth, to simplify the task of measuring the performance impact of new solution methods and/or formulations, UnitCommitment.jl includes automated benchmark scripts to perform statistic tests.

We refer to the package documentation for more details [160]. The package is being developed openly and collaboratively on GitHub [161], and the task force strongly welcomes comments and suggestions, as well as code and instance contributions from industry and academia.

VI. CONCLUSION

This paper summarizes the technical activities of the IEEE Task Force on Solving Large Scale Optimization Problems in Electricity Market and Power System Applications. It first reviews the state-of-the-art of SCUC business model, its mathematical formulations, and solution techniques in solving electricity market clearing problems. It then investigates the emerging challenges of future market clearing problems and presents efforts in building benchmark mathematical and business models.

In view of the rapid transformation being witnessed by the industry, the Task Force recommends the following focus areas for future research:

- Emerging new resource modeling and formulation (e.g., DER, storage, multi-configuration resources), as well as distributed or hybrid (a mixture of centralized and distributed) architecture.
- New solution methods and techniques, including integration with machine learning. Even though commercial MILP solvers are powerful and can generally work well with proper formulation, the research community needs to work closely with the industry to be prepared for emerging challenging problems.
- Efficient interaction between optimization and network security analysis, including transmission and distribution coordination.
- With the increasing participation of inverter-based resources, reactive power and voltage issues need to be investigated within the SCUC framework.
- Managing uncertainty and variability with renewable penetration is not discussed extensively in this paper. Sub-hourly interval, advanced reserve models, stochastic/robust optimization, and the interplay between forecasting models and SCUC are research areas to address these issues.

APPENDIX

There are many different formulations for SCUC. In this Appendix, a 3-binary formulation is used to illustrate the SCUC problem. This formulation includes three binary variables for each generator at each interval: startup, shut down, and on/off commitment. Table I is the nomenclature.

TABLE I
NOMENCLATURE

Notation	Description	Units
Sets and Indices:		
G	Set of generators	
g	Index for generators $g \in G$	
i	Index for bid segment $0 \leq i \leq I$ of generator g	
K	Set of monitored transmission constraints.	
k	Index for monitored transmission constraint flow $k \in K$.	
R	Reference node (bus).	
t	Index for time period $0 \leq t \leq T$.	
S	Set of start-up state of a generator {1-hot, 2-intermediate, 3-cold}	
s	Index for generator start up state $s \in S$	
V	Set of virtuals	
v	Index for virtual $v \in V$	
D	Set of dispatchable demand	
d	Index for dispatchable demand $d \in D$	
F	Set of fixed demand	
f	Index for fixed demand $f \in F$	
N	Set of node (bus)	
$n, n1, n2$	Indices for node (bus) $n \in N$	
n_g	Node for generator g	
n_v	Node for virtual v	
n_d	Node for dispatchable demand d	
n_f	Node for fixed demand f	
Parameters (all upper case):		
C_{gti}	Operational cost of generator g , for period t , for segment i .	S/MWh
C_{gt}^{noload}	Cost of no-load of generator g , for period t .	S/h
$C_{gs}^{startup}$	Startup cost of generator g , for start up state s	S
C_{gt}^{offFCR}	Cost of offline contingency reserve of generator g , for period t .	S/MWh
C_{gt}^{reg}	Cost of regulation reserve of generator g , for period t .	S/MWh
C_{gt}^{onCR}	Cost of online contingency reserve of generator g , for period t .	S/MWh
p_{gt}^{max}	Real power maximum output of generator g in period t .	MW
p_{gti}^{max}	Real power maximum output for segment i of generator g .	MW
p_{gt}^{min}	Real power minimum output of generator g in period t .	MW
TD_g	Minimum down time of generator g	h
TU_g	Minimum up time of generator g	h
T_{gs}^{SU}	Startup time for generator g and start-up status s	h
p_k^{max}	Real power max limit for transmission constraint k .	MW
p_k^{min}	Real power min limit for transmission constraint k ;	MW
$Sens_{kn}^R$	Sensitivity of monitored transmission constraint k for an injection at node (bus) n with the withdrawal at node (bus) R (reference bus).	
$PR_g^{max,reg}$	Maximum regulation capacity of generator g .	MW
$PR_g^{max,onCR}$	Maximum online contingency reserve capacity of generator g .	MW
$PR_g^{max,offFCR}$	Maximum offline contingency reserve capacity of generator g .	MW
R_{gt}^{SD}	Shutdown capacity of generator g in period t	MW
R_{gt}^{SU}	Startup capacity of generator g in period t	MW
R_{gt}	Maximum ramp up and down capability in one dispatch interval	MW
Req_t^{CR}	Contingency reserve requirement in period t ;	MW
Req_t^{onCR}	Online contingency reserve requirement in period t ;	MW
Req_t^{Reg}	Regulation reserve minimum requirement for period t .	MW
M_v	Multiplier of virtual v (+1 for virtual supplier and -1 for virtual demand)	
p_{vt}^{max}	Real power maximum output of virtual v in period t .	MW
p_{dt}^{max}	Real power maximum output of dispatchable demand d in period t .	MW
P_{ft}	Real power of fixed demand f in period t	MW
C_{vt}	Cost of virtual v , for period t .	S/MWh
C_{dt}	Cost of dispatchable demand d , for period t .	S/MWh
Variables (mostly lower case):		
p_{gt}	Real power output of generator g in period t (base case).	MW
p_{gti}	Real power output for segment i of generator g in period t .	MW
p_{vt}	Real power output of virtual v in period t (base case).	MW
p_{dt}	Real power output of dispatchable demand d in period t (base case).	MW
r_{gt}^{offFCR}	Ten-minute offline contingency reserve for generator g in period t	MW
r_{gt}^{reg}	Five-minute regulation reserve for generator g in period t	MW
r_{gt}^{onCR}	Ten-minute online contingency reserve for generator g in period t	MW
u_{gt}	Unit commitment binary variable for generator g in period t	
v_{gt}	Startup binary variable for generator g in period t	
w_{gt}	Shut down binary variable for generator g in period t	
δ_{gst}	Binary variable for startup type s of generator g in period t	

The 3-binary SCUC formulation:

Minimize :

$$f = \sum_{\forall gt} \left[C_g^{mload} u_{gt} + \sum_{\forall s \in S} (C_{gs}^{startup} \delta_{gst}) + \sum_{\forall i} (C_{gti} p_{gti}) + C_{gt}^{REG} r_{gt}^{REG} + C_{gt}^{onCR} r_{gt}^{onCR} + C_{gt}^{offCR} r_{gt}^{offCR} \right] + \sum_{\forall vt} (M_v C_{vt} p_{vt}) - \sum_{\forall dt} (C_{dt} p_{dt}). \quad (1)$$

s.t.

$$\sum_{g \in G} p_{gt} + \sum_{v \in V} M_v p_{vt} - \sum_{d \in D} p_{dt} = \sum_{f \in F} P_{ft} \quad \forall t \quad (2)$$

$$\sum_{g \in G} r_{gt}^{reg} \geq Req_t^{Reg} \quad \forall t \quad (3)$$

$$\sum_{g \in G} (r_{gt}^{reg} + r_{gt}^{onCR}) \geq Req_t^{Reg} + Req_t^{onCR} \quad \forall t \quad (4)$$

$$\sum_{g \in G} (r_{gt}^{reg} + r_{gt}^{onCR} + r_{gt}^{offCR}) \geq Req_t^{Reg} + Req_t^{CR} \quad \forall t \quad (5)$$

$$P_k^{min} \leq \sum_{g \in G} p_{gt} Sens_{k,n_g}^R + \sum_{v \in V} M_v p_{vt} Sens_{k,n_v}^R - \sum_{d \in D} p_{dt} Sens_{k,n_d}^R - \sum_{f \in F} P_{ft} Sens_{k,n_f}^R \leq P_k^{max}, \quad \forall k, \forall t \quad (6)$$

$$\sum_{i=t-TU_g+1}^t v_{g,i} \leq u_{gt} \quad \forall g, t \in [TU_g, T] \quad (7)$$

$$\sum_{i=t-TD_g+1}^t w_{g,i} \leq 1 - u_{gt} \quad \forall g, t \in [TD_g, T] \quad (8)$$

$$u_{gt} - u_{g,t-1} = v_{gt} - w_{gt} \quad \forall g, t \quad (9)$$

$$\delta_{gst} \leq \sum_{i=T_g^{SU}}^{T_g^{SU}-1} w_{g,t-i}, \quad \forall g, t \in [T_g^{SU}, T], s \in [1, 2] \quad (10)$$

$$\sum_{s \in S} \delta_{gst} = v_{gt} \quad \forall g, t \quad (11)$$

$$u_{gt}, v_{gt}, w_{gt}, \delta_{g,1,t}, \delta_{g,2,t}, \delta_{g,3,t} \in \{0, 1\} \quad \forall g, t \quad (12)$$

$$p_{gt} + r_{gt}^{REG} + r_{gt}^{onCR} \leq P_{gt}^{max} u_{gt} \quad \forall g, t \quad (13)$$

$$p_{gt} - r_{gt}^{REG} \geq P_{gt}^{min} u_{gt} \quad \forall g, t \quad (14)$$

$$p_{gt} - p_{g,t-1} \leq R_{gt} u_{g,t-1} + R_{gt}^{SU} v_{gt} \quad \forall g, t \quad (15)$$

$$p_{g,t-1} - p_{gt} \leq R_{gt} u_{gt} + R_{gt}^{SD} w_{gt} \quad \forall g, t \quad (16)$$

$$0 \leq p_{gti} \leq P_{gti}^{max} u_{gt} \quad \forall g, t, i \quad (17)$$

$$p_{gt} = \sum_{\forall i} (p_{gti}) \quad \forall g, t \quad (18)$$

$$0 \leq r_{gt}^{REG} \leq P_{gt}^{max,reg} u_{gt} \quad \forall g, t \quad (19)$$

$$0 \leq r_{gt}^{onCR} \leq P_{gt}^{max,onCR} u_{gt} \quad \forall g, t \quad (20)$$

$$0 \leq r_{gt}^{offCR} \leq P_{gt}^{max,offCR} (1 - u_{gt}) \quad \forall g, t \quad (21)$$

Constraints (2)–(6) are explicit representations of the system operating constraints (SCUC.2) above, and constraints (7)–(19) are explicit representations of the operating constraints for individual generators (SCUC.3) above. Specifically, constraints (2) represent the total system energy balance, constraints (3) are the regulation reserve requirements, constraints (4) are the “spinning” or “on” contingency reserve requirements, and constraints (5) are the operating reserve requirements. The reserve requirement constraints (3)–(5) are “stacked” in such a way that a higher-quality reserve product can be utilized to fulfill the requirement for a lower-quality reserve product. In addition to giving the optimizer more flexibility in meeting reserve requirements, this also ensures that the reserves, when priced, will be in the order of reserve quality. Constraints (6) describe the PTDF-based security requirements.

Turning to the generator constraints, constraints (7) are the minimum up-time requirement, constraints (8) are the minimum down-time requirements, constraints (9) are the “logical” requirements linking “on” and “off” statuses with start-up and shut-down decisions, ensuring that a start-up (i.e., $v_{gt} = 1$) switches the status of the generator from “off” to “on” and a shutdown similarly switches the generator status, constraints (10) enforce when a “hot” or “warm” start is permitted given the last shut-down period, constraints (11) force exactly one start-up type to be chosen when the unit starts, and constraints (12) impose the binary restriction on the indicator variables (on, start, stop, start-type).

Finally, the constraints involving the continuous generator variables are presented. Constraints (13) ensure that the total of both dispatch and reserve procurement does not exceed the generator’s maximum capacity; constraints (14) similarly ensure energy and reserve dispatch not to go lower than a generator’s rated capacity. Together, constraints (13) and (14) enforce that a generator only produces power when it is “on”, i.e., $u_{gt} = 1$. Constraints (15) and (16) are ramping constraints, which enforce that the power output of an individual generator does not change too rapidly between successive periods, including start-up and shut-down ramping when the generator is turned on or off. Constraints (17) and (18), along with the objective, model the convex piecewise linear cost curve. Finally, constraints (19) and (20) place operational bounds on the amount of reserve that can be procured when a generator is on, and constraint (21) limits the amount of reserve procured when a generator is off.

REFERENCES

- [1] B. Carlson et al., “MISO unlocks billions in savings through the application of operations research for energy and ancillary services markets,” *Interfaces*, vol. 42, no. 1, pp. 58–73, Jan./Feb. 2012.
- [2] M. Shahidehpour and M. Marwali, *Maintenance Scheduling in a Deregulated Power System*. London, U.K.: Kluwer Publishers, 2000.
- [3] Y. Chen, D. Savageau, F. Wang, and A. Casto, “Voltage and local reliability commitment under electricity market operations,” in *Proc. IEEE Power Energy Soc. Gen. Meeting*, 2016, pp. 1–5.
- [4] E. Litvinov, T. Zheng, G. Rosenwald, and P. Shamsollahi, “Marginal loss modeling in LMP calculation,” *IEEE Trans. Power Syst.*, vol. 19, no. 2, pp. 880–888, May 2004.
- [5] Y. Xia, M. Marwali, and J. H. Chow, “A two-stage MIP based optimization framework for unit commitment and energy pricing,” in *Proc. Power Energy Conf. at Illinois*, Feb. 2015, pp. 1–6.

- [6] C. Nguyen, L. Wu, M. Marwali, and R. Mukerji, "Small resource integration challenges for large-scale SCUC," in *Energy Markets and Responsive Grids. The IMA Volumes in Mathematics and Its Applications*, vol. 162, S. Meyn, T. Samad, I. Hiskens, and J. Stoustrup, Eds., New York, NY, USA: Springer, 2018, pp. 177–193, doi: [10.1007/978-1-4939-7822-9_8](https://doi.org/10.1007/978-1-4939-7822-9_8).
- [7] B. Gisin, Q. Gu, and J. David, "Factors impacting large-scale security constrained unit commitment performance and day-ahead market software design," in *Proc. FERC Tech. Conf.*, Jun. 2020. [Online]. Available: https://www.ferc.gov/sites/default/files/2020-08/M3-3_Gisin.pdf
- [8] S. Y. Abujarad, M. W. Mustafa, and J. J. Jamian, "Recent approaches of unit commitment in the presence of intermittent renewable energy resources: A review," *Renewable Sustain. Energy Rev.*, vol. 70, pp. 215–223, 2017.
- [9] A. Sun, *Advances in Electric Power Systems: Robustness, Adaptability, and Fairness*. Cambridge, MA, USA: Massachusetts Inst. Technol., 2011.
- [10] W. Van Ackooij, I. Danti Lopez, A. Frangioni, F. Lacalandra, and M. Tahanan, "Large-scale unit commitment under uncertainty: An updated literature survey," *Ann. Operations Res.*, vol. 271, pp. 11–85, 2018.
- [11] FERC 2222, "Participation of distributed energy resource aggregations in markets operated by regional transmission organizations and independent system operators," 2020, [Online]. Available: <https://www.ferc.gov/sites/default/files/2020-09/E-10.pdf>
- [12] "FERC order 764," Jun. 2012, Accessed: Oct. 20, 2022. [Online]. Available: <https://www.ferc.gov/sites/default/files/2020-06/OrderNo.764.pdf>
- [13] Y. Fu, Z. Li, and L. Wu, "Modeling and solution of the large-scale security-constrained unit commitment," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 3524–3533, Nov. 2013.
- [14] Y. Fu and M. Shahidehpour, "Fast SCUC for large-scale power systems," *IEEE Trans. Power Syst.*, vol. 22, no. 4, pp. 2144–2151, Nov. 2007.
- [15] Z. Li, W. Wu, J. Wang, B. Zhang, and T. Zheng, "Transmission-constrained unit commitment considering combined electricity and district heating networks," *IEEE Trans. Sustain. Energy*, vol. 7, no. 2, pp. 480–492, Apr. 2016.
- [16] G. Morales-España, C. M. Correa-Posada, and A. Ramos, "Tight and compact MIP formulation of configuration-based combined-cycle units," *IEEE Trans. Power Syst.*, vol. 31, no. 2, pp. 1350–1359, Mar. 2016.
- [17] R. E. Bohn, M. C. Caramanis, and F. C. Schweppe, "Optimal pricing in electrical networks over space and time," *RAND J. Econ.*, vol. 15, no. 3, 1984, pp. 360–376. [Online]. Available: <https://doi.org/10.2307/2555444>
- [18] B. Gisin, Q. Gu, J. V. Mitsche, S. Tam, and H. Chen, "'Perfect dispatch' - as the measure of PJM real time grid operational performance," in *Proc. IEEE PES Gen. Meeting*, 2010, pp. 1–8.
- [19] A. S. Xavier, F. Qiu, F. Wang, and P. R. Thimmapuram, "Transmission constraint filtering in large-scale security-constrained unit commitment," *IEEE Trans. Power Syst.*, vol. 34, no. 3, pp. 2457–2460, May 2019.
- [20] P. A. Ruiz, E. Goldis, A. M. Rudkevich, M. C. Caramanis, C. R. Philbrick, and J. M. Foster, "Security-constrained transmission topology control MILP formulation using sensitivity factors," *IEEE Trans. Power Syst.*, vol. 32, no. 2, pp. 1597–1605, Mar. 2017.
- [21] D. A. Tejada-Arango, S. Lumbrales, P. Sánchez-Martín, and A. Ramos, "Which unit-commitment formulation is best? A comparison framework," *IEEE Trans. Power Syst.*, vol. 35, no. 4, pp. 2926–2936, Jul. 2020.
- [22] G. Morales-España, J. M. Latorre, and A. Ramos, "Tight and compact MILP formulation for the thermal unit commitment problem," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 4897–4908, Nov. 2013.
- [23] J. Ostrowski, M. F. Anjos, and A. Vannelli, "Tight mixed integer linear programming formulations for the unit commitment problem," *IEEE Trans. Power Syst.*, vol. 27, no. 1, pp. 39–46, Feb. 2012.
- [24] H. P. Williams, *Model Building in Mathematical Programming*, 5th ed., New York, NY, USA: Wiley, 2013.
- [25] G. Morales-España, C. Gentile, and A. Ramos, "Tight MIP formulations of the power-based unit commitment problem," *OR Spectr.*, vol. 37, no. 4, pp. 929–950, 2015.
- [26] L. L. Garver, "Power generation scheduling by integer programming-development of theory," *Trans. Amer. Inst. Elect. Engineers Power App. Syst., Part III*, vol. 81, no. 3, pp. 730–734, 1962.
- [27] T. S. Dillon, K. W. Edwin, H. D. Kochs, and R. J. Taud, "Integer programming approach to the problem of optimal unit commitment with probabilistic reserve determination," *IEEE Trans. Power App. Syst.*, vol. PAS-97, no. 6, pp. 2154–2166, Nov. 1978.
- [28] M. Carrión and J. M. Arroyo, "A computationally efficient mixed-integer linear formulation for the thermal unit commitment problem," *IEEE Trans. Power Syst.*, vol. 21, no. 3, pp. 1371–1378, Aug. 2006.
- [29] S. Atakan, G. Lulli, and S. Sen, "A state transition MIP formulation for the unit commitment problem," *IEEE Trans. Power Syst.*, vol. 33, no. 1, pp. 736–748, Jan. 2018.
- [30] L. Yang, C. Zhang, J. Jian, K. Meng, Y. Xu, and Z. Dong, "A novel projected two-binary-variable formulation for unit commitment in power systems," *Appl. Energy*, vol. 187, pp. 732–745, 2017.
- [31] J. Lee, J. Leung, and F. Margot, "Min-up/min-down polytopes," *Discrete Optim.*, vol. 1, no. 1, pp. 77–85, 2004.
- [32] A. Frangioni, C. Gentile, and F. Lacalandra, "Tighter approximated MILP formulations for unit commitment problems," *IEEE Trans. Power Syst.*, vol. 24, no. 1, pp. 105–113, Feb. 2009.
- [33] B. Yan et al., "A systematical formulation tightening approach for unit commitment problems," *IEEE Trans. Power Syst.*, vol. 35, no. 1, pp. 782–794, Jan. 2020.
- [34] J. Telgen, "Redundant and nonbinding constraints in linear programming problems," in *Working Paper*, Rotterdam, The Netherlands: Erasmus Univ. Rotterdam, 1977.
- [35] I. Ioslovich, "Robust reduction of a class of large-scale linear programs," *SIAM J. Optim.*, vol. 12, no. 1, pp. 262–282, 2001.
- [36] P. Sumathi and S. Paulraj, "Identification of redundant constraints in large scale linear programming problems with minimal computational effort," *Appl. Math. Sci.*, vol. 7, no. 80, pp. 3963–3974, 2013.
- [37] G. L. Thompson, F. M. Tonge, and S. Zions, "Techniques for removing nonbinding constraints and extraneous variables from linear programming problems," *Manage. Sci.*, vol. 12, no. 7, pp. 588–608, 1966.
- [38] N. Langrene, W. van Ackooij, and F. Breant, "Dynamic constraints for aggregated units: Formulation and application," *IEEE Trans. Power Syst.*, vol. 26, no. 3, pp. 1349–1356, Aug. 2011.
- [39] J. Meus, K. Poncelet, and E. Delarue, "Applicability of a clustered unit commitment model in power system modeling," *IEEE Trans. Power Syst.*, vol. 33, no. 2, pp. 2195–2204, Mar. 2018.
- [40] D. Rajan and S. Takriti, "Minimum up/down polytopes of the unit commitment problem with start-up costs," IBM, Armonk, NY, USA, Tech Rep. RC23628, 2005.
- [41] K. Pan and Y. Guan, "A polyhedral study of the integrated minimum-up/-down time and ramping polytope," Apr. 2016. [Online]. Available: <https://arxiv.org/abs/1604.02184>
- [42] K. Pan, Y. Guan, J. P. Watson, and J. Wang, "Strengthened MILP formulation for certain gas turbine unit commitment problems," *IEEE Trans. Power Syst.*, vol. 31, no. 2, pp. 1440–1448, Mar. 2016.
- [43] Y. Guan, K. Pan, and K. Zhou, "Polynomial time algorithms and extended formulations for unit commitment problems," *IIEE Trans.*, vol. 50, no. 8, pp. 735–751, 2018.
- [44] P. Bendotti, P. Fouilhoux, and C. Rottner, "The min-up/min-down unit commitment polytope," *J. Combinatorial Optim.*, vol. 36, no. 3, pp. 1024–1058, 2018.
- [45] L. Wu, "Accelerating NCUC via binary variable-based locally ideal formulation and dynamic global cuts," *IEEE Trans. Power Syst.*, vol. 31, no. 5, pp. 4097–4107, Sep. 2016.
- [46] B. Knueven, J. Ostrowski, and J. P. Watson, "On mixed-integer programming formulations for the unit commitment problem," *INFORMS J. Comput.*, vol. 32, no. 4, pp. 857–876, 2020.
- [47] Y. Chen and F. Wang, "MIP formulation improvement for large scale security constrained unit commitment with configuration based combined cycle modeling," *Elect. Power Syst. Res.*, vol. 148, pp. 147–154, Jul. 2017.
- [48] S. Virmani, E. C. Adrian, K. Imhof, and S. Mukherjee, "Implementation of a Lagrangian relaxation based unit commitment problem," *IEEE Trans. Power Syst.*, vol. 4, no. 4, pp. 1373–1380, Nov. 1989.
- [49] M. A. Bragin, P. B. Luh, J. H. Yan, N. Yu, and G. A. Stern, "Convergence of the surrogate Lagrangian relaxation method," *J. Optim. Theory Appl.*, vol. 164, no. 1, pp. 173–201, 2015.
- [50] M. A. Bragin, P. B. Luh, B. Yan, and X. Sun, "A scalable solution methodology for mixed-integer linear programming problems arising in automation," *IEEE Trans. Automat. Sci. Eng.*, vol. 16, no. 2, pp. 531–541, Apr. 2019.
- [51] K. Kim, A. Botterud, and F. Qiu, "Temporal decomposition for improved unit commitment in power system production cost modeling," *IEEE Trans. Power Syst.*, vol. 33, no. 5, pp. 5276–5287, Sep. 2018.
- [52] C. Barrows, M. Hummon, W. Jones, and E. Hale, "Time domain partitioning of electricity production cost simulations," Nat. Renewable Energy Lab., Golden, CO, USA, Tech. Rep. NREL/TP-6A20-60969, Jan. 2015.
- [53] M. J. Feizollahi, M. Costley, S. Ahmed, and S. Grijalva, "Large-scale decentralized unit commitment," *Int. J. Elect. Power Energy Syst.*, vol. 73, pp. 97–106, 2015.

- [54] Á. S. Xavier, F. Qiu, and S. Ahmed, "Learning to solve large-scale security-constrained unit commitment problems," *INFORMS J. Comput.*, vol. 33, no. 2, pp. 739–756, 2021.
- [55] B. Knueven, J. Ostrowski, and J. Wang, "The ramping polytope and cut generation for the unit commitment problem," *INFORMS J. Comput.*, vol. 30, no. 4, pp. 739–749, 2018.
- [56] R. Baldick and D. Chatterjee, "Coordinated dispatch of regional transmission organizations: Theory and example," *Comput. Oper. Res.*, vol. 41, pp. 319–332, 2014.
- [57] A. S. Xavier, F. Qiu, and S. S. Dey, "Decomposable formulation of transmission constraints for decentralized power systems optimization," Mar. 2021. [Online]. Available: <https://arxiv.org/abs/2001.07771>
- [58] T. Berthold, "Measuring the impact of primal heuristics," *Oper. Res. Lett.*, vol. 41, no. 6, pp. 611–614, 2013.
- [59] A. Lodi, "Mixed integer programming computation," in *50 in Years of Integer Programming 1958–2008*. Berlin, Germany: Springer-Verlag, 2010, pp. 619–645.
- [60] E. Parrilla and J. García-González, "Improving the B&B search for large-scale hydrothermal weekly scheduling problems," *Int. J. Elect. Power Energy Syst.*, vol. 28, no. 5, pp. 339–348, 2006.
- [61] M. Fischetti and A. Lodi, "Heuristics in mixed integer programming," in *Wiley Encyclopedia of Operations Research and Management Science*, Feb. 2011. [Online]. Available: <https://onlinelibrary.wiley.com/doi/10.1002/9780470400531.eorms0376>
- [62] M. Fischetti, F. Glover, and A. Lodi, "The feasibility pump," *Math. Program.*, vol. 104, no. 1, pp. 91–104, 2005.
- [63] Y. Bai, H. Zhong, Q. Xia, Y. Xin, and C. Kang, "Inducing-objective-function-based method for long-term SCUC with energy constraints," *Int. J. Elect. Power Energy Syst.*, vol. 63, pp. 971–978, 2014.
- [64] M. Fischetti and A. Lodi, "Local branching," *Math. Program.*, vol. 98, no. 1, pp. 23–47, 2003.
- [65] M. Fischetti, C. Polo, and M. Scantamburlo, "A local branching heuristic for mixed-integer programs with 2-level variables, with an application to a telecommunication network design problem," *Networks*, vol. 44, no. 2, pp. 61–72, 2004.
- [66] E. Danna, E. Rothberg, and C. L. Pape, "Exploring relaxation induced neighborhoods to improve MIP solutions," *Math. Program.*, vol. 102, no. 1, pp. 71–90, 2005.
- [67] D. Gerard, M. Köppe, and Q. Louveaux, "Guided dive for the spatial branch-and-bound," *J. Glob. Optim.*, vol. 68, no. 4, pp. 685–711, 2017.
- [68] G. Chicco and A. Mazza, "Metaheuristic optimization of power and energy systems: Underlying principles and main issues of the 'rush to heuristics,'" *Energies*, vol. 13, no. 19, 2020, Art. no. 5097.
- [69] D. N. Simopoulos, S. D. Kavatza, and C. D. Vournas, "Unit commitment by an enhanced simulated annealing algorithm," *IEEE Trans. Power Syst.*, vol. 21, no. 1, pp. 68–76, Feb. 2006.
- [70] D. N. Simopoulos, S. D. Kavatza, and C. D. Vournas, "Reliability constrained unit commitment using simulated annealing," *IEEE Trans. Power Syst.*, vol. 21, no. 4, pp. 1699–1706, Nov. 2006.
- [71] L. Shi, J. Hao, J. Zhou, and G. Xu, "Ant colony optimization algorithm with random perturbation behavior to the problem of optimal unit commitment with probabilistic spinning reserve determination," *Elect. Power Syst. Res.*, vol. 69, no. 2/3, pp. 295–303, 2004.
- [72] E. Gil, J. Bustos, and H. Rudnick, "Short-term hydrothermal generation scheduling model using a genetic algorithm," *IEEE Trans. Power Syst.*, vol. 18, no. 4, pp. 1256–1264, Nov. 2003.
- [73] C. E. Zoumas, A. G. Bakirtzis, J. B. Theocharis, and V. Petridis, "A genetic algorithm solution approach to the hydrothermal coordination problem," *IEEE Trans. Power Syst.*, vol. 19, no. 3, pp. 1356–1364, Aug. 2004.
- [74] Z. Yang et al., "A binary symmetric based hybrid meta-heuristic method for solving mixed integer unit commitment problem integrating with significant plug-in electric vehicles," *Energy*, vol. 170, pp. 889–905, 2019.
- [75] Y. Chen, A. Casto, F. Wang, Q. Wang, X. Wang, and J. Wan, "Improving large scale day-ahead security constrained unit commitment performance," *IEEE Trans. Power Syst.*, vol. 31, no. 6, pp. 4732–4743, Nov. 2016.
- [76] Y. Chen, F. Wang, Y. Ma, and Y. Yao, "A distributed framework for solving and benchmarking security constrained unit commitment with warm start," *IEEE Trans. Power Syst.*, vol. 35, no. 1, pp. 711–720, Jan. 2020.
- [77] Y. Chen, F. Pan, J. Holzer, E. Rothberg, Y. Ma, and A. Veeramany, "A high performance computing based market economics driven neighborhood search and polishing algorithm for security constrained unit commitment," *IEEE Trans. Power Syst.*, vol. 36, no. 1, pp. 292–302, Jan. 2021.
- [78] Y. Chen, F. Pan, J. Holzer, A. Veeramany, and Z. Wu, "On improving efficiency of electricity market clearing software with a concurrent high performance computer based security constrained unit commitment solver," in *Proc. IEEE PES Gen. Meeting*, 2021, pp. 1–5.
- [79] G. Anders and A. Morched, "Commitment techniques for combined-cycle units, CEATI," Research Rep. T053700-3103, Dec. 2005 [Online]. Available: https://www.nyiso.com/documents/20142/1399986/3103_Combinment_Techniques_for_CCGUs.pdf/22aa3b14-8c53-5048-9aed-b133528dc703
- [80] H. Hui, C.-N. Yu, F. Gao, and R. Surendran, "Combined cycle resource scheduling in ERCOT nodal market," in *Proc. IEEE PES Gen. Meeting*, 2011, pp. 1–8.
- [81] C. Liu, M. Shahidehpour, Z. Li, and M. Fotuhi-Firuzabad, "Component and mode models for the short-term scheduling of combined-cycle units," *IEEE Trans. Power Syst.*, vol. 24, no. 2, pp. 976–990, May 2009.
- [82] Y. Chen, F. Wang, and C. Wang, "Enhanced combined cycle modeling," 2017. [Online]. Available: <https://www.misoenergy.org/Library/Repository/Meeting%20Material/Stakeholder/MSC/2017/20170810/20170810%20MSC%20Item%2008%20Enhanced%20Modeling%20of%20CC%20Generators.pdf>
- [83] "MISO enhanced combined cycle task team, MISO enhanced combined cycle white paper i research and development report," Jan. 2018. [Online]. Available: <https://cdn.misoenergy.org/20180209%20ECCCT%20White%20Paper%201%20Research%20&%20Development%20Report118729.pdf>
- [84] M. Tamayo, X. Yu, X. Wang, and J. Zhang, "Configuration based combined cycle model in market resource commitment," in *Proc. IEEE Power Energy Soc. Gen. Meeting*, 2013, pp. 1–5.
- [85] SPP, Member "Impacting project overview PR20150019 enhanced combined cycle, gas electric harmonization markets release 1.19.1.20, RR184, RR199," 2017. [Online]. Available: <https://www.spp.org/documents/31770/enhanced%20combined%20cycle%20mipo%20v4.0%20clean.pdf>
- [86] L. Fan and Y. Guan, "An edge-based formulation for combined-cycle units," *Trans. Power Syst.*, vol. 31, no. 3, pp. 1809–1819, May 2016.
- [87] L. Fan, K. Pan, Y. Guan, Y. Chen, and X. Wang, "Strengthened MILP formulation for combined-cycle units," *Optimization Online*, 2016. [Online]. Available: http://www.optimization-online.org/DB_FILE/2016/08/5574.pdf
- [88] C. Dai, Y. Chen, F. Wang, J. Wan, and L. Wu, "A configuration-component based hybrid model for combined-cycle units in MISO day-ahead market," *Trans. Power Syst.*, vol. 34, no. 2, pp. 883–896, Mar. 2019.
- [89] B. Hua, B. Huang, R. Baldick, and Y. Chen, "Tight formulation of transition ramping of combined cycle units," *Trans. Power Syst.*, vol. 35, no. 3, pp. 2167–2175, May 2020.
- [90] S. Zhang, H. Ye, F. Wang, Y. Chen, S. Rose, and Y. Ma, "Data-aided offline and online screening for security constraint," *IEEE Trans. Power Syst.*, vol. 36, no. 3, pp. 2614–2622, May 2021.
- [91] X. Sun, P. B. Luh, M. A. Bragin, Y. Chen, J. Wan, and F. Wang, "A novel decomposition and coordination approach for large day-ahead unit commitment with combined cycle units," *IEEE Trans. Power Syst.*, vol. 33, no. 5, pp. 5297–5308, Sep. 2018.
- [92] FERC Order 841, *Electric storage participation in markets operated by regional transmission organizations and independent system operators*, May 23, 2019. [Online]. Available: <https://www.federalregister.gov/documents/2019/05/23/2019-10742/electric-storage-participation-in-markets-operated-by-regional-transmission-organizations-and-independent-system-operators>
- [93] R. Gramlich, M. Goggin, and J. Burwen, "Enabling versatility: Allowing hybrid resources to deliver their full value to customers," *Energy Storage Assoc. Rep.*, Sep. 2019. [Online]. Available: <https://energystorage.org/wp/wp-content/uploads/2019/09/2019.9.16-GridStrategies-ESA-White-Paper-on-Hybrid-Resources.pdf>
- [94] A. Giacomoni, Q. Gu, and B. Gisin, "Optimizing hydroelectric pumped storage in PJM's day-ahead energy market," in *Proc. FERC Tech. Conf.*, Jun. 2020.
- [95] R. Baldick, Y. Chen, and B. Huang, "Optimization formulations for storage devices," working paper, Jul. 2021. [Online]. Available: http://www.optimization-online.org/DB_FILE/2021/07/8502.pdf
- [96] E. D. Castronuovo and J. A. P. Lopes, "On the optimization of the daily operation of a wind-hydro power plant," *IEEE Trans. Power Syst.*, vol. 19, no. 3, pp. 1599–1606, Aug. 2004.
- [97] Á. J. Duque, E. D. Castronuovo, I. Sánchez, and J. Usaola, "Optimal operation of a pumped-storage hydro plant that compensates the imbalances of a wind power producer," *Elect. Power Syst. Res.*, vol. 81, no. 9, pp. 1767–1777, 2011.

- [98] M. Korpaas, A. T. Holen, and R. Hildrum, "Operation and sizing of energy storage for wind power plants in a market system," *Int. J. Elect. Power Energy Syst.*, vol. 25, no. 8, pp. 599–606, 2003.
- [99] E. D. Castronuovo and J. A. P. Lopes, "Optimal operation and hydro storage sizing of a wind-hydro power plant," *Int. J. Elect. Power Energy Syst.*, vol. 26, no. 10, pp. 771–778, 2004.
- [100] P. D. Brown, J. A. Pecas Lopes, and M. A. Matos, "Optimization of pumped storage capacity in an isolated power system with large renewable penetration," *IEEE Trans. Power Syst.*, vol. 23, no. 2, pp. 523–531, May 2008.
- [101] E. Ni, P. B. Luh, and S. Rourke, "Optimal integrated generation bidding and scheduling with risk management under a deregulated power market," *IEEE Trans. Power Syst.*, vol. 19, no. 1, pp. 600–609, Feb. 2004.
- [102] R. Jiang, J. Wang, and Y. Guan, "Robust unit commitment with wind power and pumped storage hydro," *IEEE Trans. Power Syst.*, vol. 27, no. 2, pp. 800–810, May 2012.
- [103] M. E. Khodayar, M. Shahidehpour, and L. Wu, "Enhancing the dispatchability of variable wind generation by coordination with pumped-storage hydro units in stochastic power systems," *IEEE Trans. Power Syst.*, vol. 28, no. 3, pp. 2808–2818, Aug. 2013.
- [104] N. Li and K. W. Hedman, "Enhanced pumped hydro storage utilization using policy functions," *IEEE Trans. Power Syst.*, vol. 32, no. 2, pp. 1089–1102, Mar. 2017.
- [105] B. Huang, Y. Chen, and R. Baldick, "A configuration based pumped storage hydro model in the MISO day-ahead market," *IEEE Trans. Power Syst.*, vol. 37, no. 1, pp. 132–141, Jan. 2022.
- [106] C. Shao, X. Wang, X. Wang, C. Du, C. Dang, and S. Liu, "Cooperative dispatch of wind generation and electric vehicles with battery storage capacity constraints in SCUC," *IEEE Trans. Smart Grid*, vol. 5, no. 5, pp. 2219–2226, Sep. 2014.
- [107] P. Yang and A. Nehorai, "Joint optimization of hybrid energy storage and generation capacity with renewable energy," *IEEE Trans. Smart Grid*, vol. 5, no. 4, pp. 1566–1574, Jul. 2014.
- [108] Z. Li, Q. Guo, H. Sun, and J. Wang, "Sufficient conditions for exact relaxation of complementarity constraints for storage-concerned economic dispatch," *IEEE Trans. Power Syst.*, vol. 31, no. 2, pp. 1653–1654, Mar. 2016.
- [109] Z. Li, Q. Guo, H. Sun, and J. Wang, "Further discussions on sufficient conditions for exact relaxation of complementarity constraints for storage-concerned economic dispatch," [Online]. Available: <https://arxiv.org/abs/1505.02493>
- [110] Y. Chen and R. Baldick, "Battery storage formulation and impact on day ahead security constrained unit commitment," *IEEE Trans. Power Syst.*, vol. 37, no. 5, pp. 3995–4005, Sep. 2022.
- [111] S. Parhizi, "Modelling of energy storage resources in New York electricity market," in *Proc. FERC Tech. Conf.: Increase Real-Time Day-Ahead Market Efficiency Enhancing Resilience Through Improved Softw.*, 2020, pp. 2020–2026.
- [112] S. Barot and J. A. Taylor, "A concise, approximate representation of a collection of loads described by polytopes," *Int. J. Elect. Power Energy Syst.*, vol. 84, pp. 55–63, 2017.
- [113] K. Hreinsson, A. Scaglione, M. Alizadeh, and Y. Chen, "New insights from the shapley-folkman lemma on dispatchable demand in energy markets," *IEEE Trans. Power Syst.*, vol. 36, no. 5, pp. 4028–4041, Sep. 2021.
- [114] A. Kumar, S. C. Srivastava, and S. N. Singh, "A zonal congestion management approach using real and reactive power rescheduling," *IEEE Trans. Power Syst.*, vol. 19, no. 1, pp. 554–562, Feb. 2004.
- [115] K. Zuo, Y. Liu, J. Xia, Y. Yang, L. Wu, and Y. Chen, "Impact of distributed energy resource integration on real-time energy market oscillation," in *Proc. IEEE Power Energy Soc. Gen. Meeting*, 2021, pp. 1–5.
- [116] L. Wu, Y. Liu, Y. Yang, and Y. Chen, "Future resource studies in the MISO system," 2020. [Online]. Available: <https://cdn.misoenergy.org/Future%20Resource%20Studies%20in%20the%20MISO%20System539337.pdf>
- [117] M. Birk, J. P. Chaves-Ávila, T. Gómez, and R. Tabors, "TSO/DSO coordination in a context of distributed energy resource penetration," 2017. [Online]. Available: <http://cepr.mit.edu/files/papers/2017-017.pdf>
- [118] CAISO, PG&E, SCE, SDG&E. "Coordination of transmission and distribution operations in a high distributed energy resource electric grid," 2017. [Online]. Available: https://gridworks.org/wp-content/uploads/2017/01/Gridworks_CoordinationTransmission.pdf
- [119] A. G. Givisiezia, K. Petroua, and L. F. Ochoaa, "A review on TSO-DSO coordination models and solution techniques," *Elect. Power Syst. Res.*, vol. 189, 2020, Art. no. 106659.
- [120] Y. Liu and L. Wu, "Integrating distributed energy resources into the independent system operators' energy market: A review," *Curr. Sustain./Renewable Energy Rep.*, vol. 8, pp. 233–241, 2021.
- [121] Y. Liu, L. Wu, Y. Chen, and J. Li, "Integrating high DER-penetrated distribution systems into ISO energy market clearing: A feasible region projection approach," *IEEE Trans. Power Syst.*, vol. 36, no. 3, pp. 2262–2272, May 2021.
- [122] Y. Liu, L. Wu, Y. Chen, J. Li, and Y. Yang, "On accurate and compact model of high DER-penetrated sub-transmission/primary distribution systems in ISO energy market," *IEEE Trans. Sustain. Energy*, vol. 12, no. 2, pp. 810–820, Apr. 2021.
- [123] W. W. Hogan, "Virtual bidding and electricity market design," [Online]. Available: https://Impmarketdesign.com/papers/Hogan_Virtual_Bidding_052516.pdf
- [124] C. Yu, V. Brandwajn, and S. Chang, "Co-optimization of congestion revenue rights in ERCOT day-ahead market," in *Proc. FERC Tech. Conf.*, Jun. 2013. [Online]. Available: <https://cms.ferc.gov/sites/default/files/2020-05/2014041125253-M2%2520-%2520Yu.pdf>
- [125] PJM, "Virtual transactions in the PJM energy markets," 2015. [Online]. Available: <http://docplayer.net/18821168-Virtual-transactions-in-the-pjm-energy-markets.html>
- [126] A. Long and A. Giacomoni, "Exploring the impacts of virtual transactions in the PJM wholesale energy market," in *Proc. IEEE Power Energy Soc. Gen. Meeting*, 2020, pp. 1–5.
- [127] J. Wu, P. B. Luh, Y. Chen, M. A. Bragin, and B. Yan, "A novel optimization approach for sub-hourly unit commitment with large numbers of generators and virtual transactions," *IEEE Trans. Power Syst.*, vol. 37, no. 5, pp. 3716–3725, Sep. 2022.
- [128] Y. C. Ho, "An ordinal optimization approach to optimal control problems," *Automatica*, vol. 35, pp. 331–338, Feb. 1999.
- [129] Y. C. Ho, Q. Zhao, and Q. Jia, *Ordinal Optimization: Soft optimization for Hard Problems*. Berlin, Germany: Springer, 2007.
- [130] N. Raghunathan et al., "Exploiting soft constraints within decomposition and coordination methods for sub-hourly unit commitment," *Int. J. Elect. Power Energy Syst.*, vol. 139, 2022, Art. no. 108023.
- [131] Q. Zhai, X. Guan, J. Cheng, and H. Wu, "Fast identification of inactive security constraints in SCUC problems," *IEEE Trans. Power Syst.*, vol. 25, no. 4, pp. 1946–1954, Nov. 2010.
- [132] A. J. Ardakani and F. Bouffard, "Identification of umbrella constraints in DC-based security-constrained optimal power flow," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 3924–3934, Nov. 2013.
- [133] X. Li, Q. Zhai, and X. Guan, "Robust transmission constrained unit commitment: A column merging method," *IET Gener., Transmiss. Distrib.*, vol. 14, no. 15, pp. 2968–2975, 2020.
- [134] Y. Yang, X. Guan, and Q. Zhai, "Fast grid security assessment with $N - k$ contingencies," *IEEE Trans. Power Syst.*, vol. 32, no. 3, pp. 2193–2203, May 2017.
- [135] Y. Yang and L. Wu, "Machine learning approaches to the unit commitment problem: Current trends, emerging challenges, and new strategies," *Elect. J.*, vol. 34, no. 1, 2021, Art. no. 106889.
- [136] "Gurobi reference manual," Accessed: Oct. 20, 2022. [Online]. Available: <https://www.gurobi.com/documentation/9.5/refman/lazy.html>
- [137] S. M. Chan and V. Brandwajn, "Partial matrix refactorization," *IEEE Trans. Power Syst.*, vol. 1, no. 1, pp. 193–199, Feb. 1986.
- [138] H. Song, T. Zheng, H. Liu, and H. Zhang, "Modeling MW-dependent ramp rate in the electricity market," in *Proc. IEEE Power Energy Soc. Gen. Meeting*, 2014, pp. 1–5.
- [139] B. Yan et al., "Effective modeling and resolution of generation-dependent ramp rates for unit commitment," in *Proc. IEEE Power & Energy Soc. Gen. Meeting*, 2017, pp. 1–5.
- [140] R. Morrison, "SOS2 constraints in GLPK," *A Note Model. Piecewise Linear Functions GLPK*, 2008. [Online]. Available: https://winglpk.sourceforge.net/media/glpk-sos2_02.pdf
- [141] P. Bendotti, P. Fouilhoux, and C. Rottner, "On the complexity of the unit commitment problem," *Annu. Oper. Res.*, vol. 274, no. 1/2, pp. 119–130, 2019.
- [142] B. Knueven, J. Ostrowski, and J.-P. Watson, "Exploiting identical generators in unit commitment," *IEEE Trans. Power Syst.*, vol. 33, no. 4, pp. 4496–4507, Jul. 2018.
- [143] E. Krall, M. Higgins, and R. P. O'Neill, "RTO unit commitment test system," Federal Energy Regulatory Commission, Jul. 2012. [Online]. Available: <https://ferc.gov/sites/default/files/2020-04/rto-COMMITMENT-TEST.pdf>
- [144] C. Barrows et al., "The IEEE reliability test system: A proposed 2019 update," *IEEE Trans. Power Syst.*, vol. 35, no. 1, pp. 119–127, Jan. 2020.
- [145] IEEE PES Task "Force on benchmarks for validation of emerging power system algorithms. Power grid lib – unit commitment," version 19.08, Accessed: 23, Jan. 2022. [Online]. Available: <https://github.com/power-grid-lib/pglib-uc/tree/v19.08>

- [146] A. Xavier, A. Kazachkov, and F. Qiu, "UnitCommitment.jl: A Julia/JuMP optimization package for security-constrained unit commitment," 2022. [Online]. Available: <https://zenodo.org/record/6857290#.Y1IYSHbMJPY>
- [147] M. Bynum et al., *Pyomo – Optimization Modeling in Python*, 3rd ed. Berlin, Germany: Springer, 2017.
- [148] M. Bynum, A. Castillo, C. Laird, B. Knueven, and J.-P. Watson, "EGRET – electrical grid research and engineering tools," Accessed: 23, Jan. 2022. [Online]. Available: <https://github.com/grid-parity-exchange/Egret>
- [149] I. Dunning, J. Huchette, and M. Lubin, "JuMP: A modeling language for mathematical optimization," *SIAM Rev.*, vol. 59, no. 2, pp. 295–320, 2017.
- [150] D. Streiffert, R. Philbrick, and A. Ott, "A mixed integer programming solution for market clearing and reliability analysis," in *Proc. IEEE Power Eng. Soc. Gen. Meeting*, vol. 3, 2005, pp. 2724–2731.
- [151] A. V. Vykhodtsev, D. Jang, Q. Wang, H. Zareipour, and W. D. Rosehart, "A review of lithium-ion battery models in techno-economic analyses of power systems," Jun. 2021. [Online]. Available: <https://arxiv.org/pdf/2106.08702.pdf>
- [152] B. Zakeri and S. Syri, "Electrical energy storage systems: A comparative life cycle cost analysis," *Renewable Sustain. Energy Rev.*, vol. 42, pp. 569–596, 2015.
- [153] H. Mohsenian-Rad, "Optimal bidding, scheduling, and deployment of battery systems in California day-ahead energy market," *IEEE Trans. Power Syst.*, vol. 31, no. 1, pp. 442–453, Jan. 2016.
- [154] F. Wankmüller, P. R. Thimmapuram, K. G. Gallagher, and A. Botterud, "Impact of battery degradation on energy arbitrage revenue of grid-level energy storage," *J. Energy Storage*, vol. 10, pp. 56–66, 2017.
- [155] N. Li, L. Chen, and S. H. Low, "Optimal demand response based on utility maximization in power networks," in *Proc. IEEE Power Energy Soc. Gen. Meeting*, 2011, pp. 1–8.
- [156] Y. Shi, B. Xu, Y. Tan, and B. Zhang, "A convex cycle-based degradation model for battery energy storage planning and operation," in *Proc. Annu. Amer. Control Conf.*, 2018, pp. 4590–4596.
- [157] A. Maheshwari, M. Heck, and M. Santarelli, "Cycle aging studies of lithium nickel manganese cobalt oxide-based batteries using electrochemical impedance spectroscopy," *Electrochimica Acta*, vol. 273, pp. 335–348, 2018.
- [158] A. Maheshwari, N. G. Paterakis, M. Santarelli, and M. Gibescu, "Optimizing the operation of energy storage using a non-linear lithium-ion battery degradation model," *Appl. Energy*, vol. 261, 2020, Art. no. 114360.
- [159] T. Achterberg and R. Wunderling, "Mixed integer programming: Analyzing 12 years of progress," in *Facets of Combinatorial Optimization*, Berlin, Germany: Springer, 2013, pp. 449–481.
- [160] Unitcommitment.jl, Oct. 20, 2022. [Online]. Available: <https://anl-ceedesa.github.io/UnitCommitment.jl>
- [161] "Optimization package for the Security-Constrained Unit Commitment Problem," Accessed: Oct. 20, 2022. [Online]. Available: <https://github.com/ANL-CEEDESA/UnitCommitment.jl>
- [162] W. W. Hager, "Updating the inverse of a matrix," *SIAM Rev.*, vol. 31, no. 2, pp. 221–239, 1989.
- [163] J. E. Beasley, "OR-Library: Distributing test problems by electronic mail," *J. Oper. Res. Soc.*, vol. 41, no. 11, pp. 1069–1072, 1990.
- [164] A. Frangioni and C. Gentile, "Solving nonlinear single-unit commitment problems with ramping constraints," *Operations Res.*, vol. 54, no. 4, pp. 767–775, 2006.
- [165] University of Washington, Dept. of Electrical Engineering, "Power systems test case archive," 2022, Accessed: Oct. 20, 2022. [Online]. Available: <https://labs.ece.uw.edu/pstca>
- [166] C. Jozs, S. Fliscounakis, J. Maeght, and P. Panciatici, "AC power flow data in MATPOWER and QCQP format: ITesla, RTE snapshots, and PEGASE," Mar. 2016. [Online]. Available: <https://arxiv.org/abs/1603.01533>
- [167] S. Fliscounakis, P. Panciatici, F. Capitanescu, and L. Wehenkel, "Contingency ranking with respect to overloads in very large power systems taking into account uncertainty, preventive and corrective actions," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 4909–4917, Nov. 2013.
- [168] J. M. Arroyo and A. J. Conejo, "Optimal response of a thermal unit to an electricity spot market," *IEEE Trans. Power Syst.*, vol. 15, no. 3, pp. 1098–1104, Aug. 2000.
- [169] P. Damcı-Kurt, S. Küçükyavuz, D. Rajan, and A. Atamtürk, "A polyhedral study of production ramping," *Math. Program.*, vol. 158, no. 1, pp. 175–205, 2016.
- [170] K. Pan and Y. Guan, "Strong formulations for multistage stochastic self-scheduling unit commitment," *Oper. Res.*, vol. 64, no. 6, pp. 1482–1498, 2016.
- [171] J. Holzer, Y. Chen, Z. Wu, F. Pan, and A. Veeramany, "Fast simultaneous feasibility test for security constrained unit commitment," Jul. 2021. [Online]. Available: <https://doi.org/10.36227/techrxiv.20280384>
- [172] D. A. Tejada-Arango, P. Sánchez-Martín, and A. Ramos, "Security constrained unit commitment using line outage distribution factors," *IEEE Trans. Power Syst.*, vol. 33, no. 1, pp. 329–337, Jan. 2018.
- [173] H. Zhou, K. Yuan, and C. Lei, "Security constrained unit commitment based on modified line outage distribution factors," *IEEE Access*, vol. 10, pp. 25258–25266, 2022.
- [174] C. M. Correa-Posada and P. Sánchez-Martín, "Security-constrained optimal power and natural-gas flow," *IEEE Trans. Power Syst.*, vol. 29, no. 4, pp. 1780–1787, Jul. 2014.
- [175] C. He, X. Zhang, T. Liu, L. Wu, and M. Shahidehpour, "Coordination of interdependent electricity grid and natural gas network—A review," *Curr. Sustain./Renewable Energy Rep.*, vol. 5, pp. 23–36, 2018.
- [176] C. He, L. Wu, T. Liu, and M. Shahidehpour, "Robust co-optimization scheduling of electricity and natural gas systems via ADMM," *IEEE Trans. Sustain. Energy*, vol. 8, no. 2, pp. 658–670, Apr. 2017.
- [177] C. Wang, W. Wei, J. Wang, L. Wu, and Y. Liang, "Equilibrium of interdependent gas and electricity markets with marginal price based bilateral energy trading," *IEEE Trans. Power Syst.*, vol. 33, no. 5, pp. 4854–4867, Sep. 2018.
- [178] L. Nan, L. Wu, T. Liu, Y. Liu, and C. He, "Vulnerability identification and evaluation of interdependent natural gas-electricity systems," *IEEE Trans. Smart Grid*, vol. 11, no. 4, pp. 3558–3569, Jul. 2020.
- [179] L. Bai, F. Li, H. Cui, T. Jiang, H. Sun, and J. Zhu, "Interval optimization based operating strategy for gas-electricity integrated energy systems considering demand response and wind uncertainty," *Appl. Energy*, vol. 167, pp. 270–279, Apr. 2016.
- [180] F. C. Schweppe, M. C. Caramanis, R. D. Tabors, and R. E. Bohn, *Spot Pricing of Electricity*. Boston, MA, USA: Kluwer Academic Publishers, 1988.
- [181] A. L. Ott, "Experience with PJM market operation, system design, and implementation," *IEEE Trans. Power Syst.*, vol. 18, no. 2, pp. 528–534, May 2003.
- [182] F. Li and R. Bo, "DCOPF-based LMP simulation: Algorithm, comparison with ACOPF, and sensitivity," *IEEE Trans. Power Syst.*, vol. 22, no. 4, pp. 1475–1485, Nov. 2007.
- [183] R. P. O'Neill, P. M. Sotkiewicz, B. F. Hobbs, M. H. Rothkopf, and W. R. Stewart Jr., "Efficient market-clearing prices in markets with nonconvexities," *Eur. J. Oper. Res.*, vol. 164, no. 1, pp. 269–285, 2005.
- [184] P. R. Gribik, W. W. Hogan, and S. L. Pope, "Market-clearing electricity prices and energy uplift," *Working Paper*, Cambridge, MA, USA: Harvard Univ., 2007.
- [185] B. Hua and R. Baldick, "A convex primal formulation for convex hull pricing," *IEEE Trans. Power Syst.*, vol. 32, no. 5, pp. 3814–3823, Sep. 2017.
- [186] Y. Yu, Y. Guan, and Y. Chen, "An extended integral unit commitment formulation and an iterative algorithm for convex hull pricing," *IEEE Trans. Power Syst.*, vol. 35, no. 6, pp. 4335–4346, Nov. 2020.
- [187] G. Liberopoulos and P. Andrianesis, "Critical review of pricing schemes in markets with non-convex costs," *Operations Res.*, vol. 64, no. 1, pp. 17–31, 2016.
- [188] P. Andrianesis, D. Bertsimas, M. C. Caramanis, and W. W. Hogan, "Computation of convex hull prices in electricity markets with non-convexities using dantzig-wolfe decomposition," *IEEE Trans. Power Syst.*, vol. 37, no. 4, pp. 2578–2589, Jul. 2022.
- [189] R. P. O'Neill and Y. Chen, "Pricing in dynamic ISO markets with unit commitment," in *Proc. Tech. Conf.*, Jun. 2021. [Online]. Available: <https://www.ferc.gov/media/t4-oneill>
- [190] Y. Chen, R. P. O'Neill, and P. Whitman, "A unified approach in solving convex hull pricing and average incremental cost pricing," [Online]. Available: http://www.optimization-online.org/DB_HTML/2020/09/8004.html, Sep. 6, 2020.
- [191] W. W. Hogan, "Demand response pricing in organized wholesale markets," [Online]. Available: <https://web.hks.harvard.edu/publications/getFile.aspx?Id=678>, May 13, 2010.
- [192] M. Hogan, "Follow the missing money: Ensuring reliability at least cost to consumers in the transition to a low-carbon power system," *Elect. J.*, vol. 30, no. 1, pp. 55–61, 2017.
- [193] F. Abbaspourtorbati, A. J. Conejo, J. Wang, and R. Cherkaoui, "Is being flexible advantageous for demands?," *IEEE Trans. Power Syst.*, vol. 32, no. 3, pp. 2337–2345, May 2017.